Fan Kit Installation Guide

Phasetronics Inc. dba Motortronics 1600 Sunshine Drive Clearwater, Florida 33765 www.motortronics.com

© 2019 by Phasetronics, all rights reserved


Copyright subsists in all Phasetronics Inc. deliverables including magnetic, optical and/or any other soft copy of these deliverables. This document may not be reproduced, in full or in part, without written permission. Enquiries about copyright of Phasetronics Inc. deliverables should be made to Phasetronics Inc. Ltd. If, by permission of the copyright owner, any part of this document is quoted, then a statement specifying the original document shall be added to the quotation. Any such quotation shall be according to the original (text, figure or table) and may not be shortened or modified.

Fan (VMX-AGY-030)

VMX-AGY-030 is designed for models VMX-AGY-101 to VMX-AGY-113. It increases the number of start/stop cycles per hour. The fan operates automatically during a soft start or soft stop and will continue to run if the heatsink temperature is $> 113 \, ^{\circ}$ F (45°C). The fan stops when the heatsink temperature has fallen below 104 $^{\circ}$ F (40°C).

Installation






Step 2. Remove blanking plug (x1)

Step 3. Fit fan as shown

Step 4. Replace screw (x1)



Step 5. Fit flying lead from fan into socket.

California Customers:

California Proposition 65 Warning

WARNING: this product and associated accessories may contain chemicals known to the State of California to cause cancer, birth defects, or other reproductive harm. For more information visit https://p65warnings.ca.gov



Solid State AC Motor Control

VMX-agility**

SIZE 1: FAN KIT INSTALLATION GUIDE

Phasetronics, Inc. dba Motortronics 1600 Sunshine Drive Clearwater, Florida 33765 USA

Tel: +1 727.573.1819 or 888.767.7792 Fax: +1 727.573.1803 or 800.548.4104

www.motortronics.com